



## EC-Attestation of Conformity

No. M8 04 07 52465 003

**Holder of Certificate:** **Gönka Klima Tesisat Insaat  
San. ve Tic. A.S.**

Göktürk Cad. No:6  
06460 Sincan-Ankara  
Turkey

**Product:** Machinery  
**Water Cooled Liquid Chiller GSSC**

**Model(s):** Series GSSC with types:  
GSSC-V 1V1, 1V2, 1V3, 1V4, 2V2, 2V3,  
2V4, 3V3, 3V4, 4V3, 4V4  
GSSC 50.1, 70.1, 100.1, 125.2, 150.2,  
200.2, 250.3, 300.3, 400.4, 500.6

**Parameters:**

Rated Voltage:	400 V
Rated Frequency:	50 Hz
Protection Class:	I
Protection against Moisture:	IP 54

**Tested according to:** EN 60204-1:1997  
EN 292-1:1991  
EN 292-2/A1:1995  
EN 294:1992  
EN 1050:1996

This EC Attestation of Conformity is issued on a voluntary basis according to Council Directive 98/37/EC relating to machinery. It confirms that the listed equipment (not annex IV equipment) complies with the principal protection requirements of the directive. See also notes overleaf.

**Test report no.:** 70068483-2

**Date,** 2004-07-08



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1



## EC-Attestation of Conformity

No. M8 04 07 52465 005

**Holder of Certificate:** **Gönka Klima Tesisat Insaat  
San. ve Tic. A.S.**  
Göktürk Cad. No:6  
06460 Sincan-Ankara  
Turkey

**Product:** **Machinery  
Hygienic climate package**

**Model(s):** **Series GHP with types:  
GHP 72, 90, 110, 120, 160, 210, 280, 320  
GHPS 71, 91, 121, 211, 321**

**Parameters:** **Rated Voltage: 400 V  
Rated Frequency: 50 Hz  
Protection Class:  
Protection against  
Moisture: IP 54**

**Tested according to:** **EN 60204-1:1997  
EN 292-1:1991  
EN 292-2/A1:1995  
EN 294:1992  
EN 1050:1996**

This EC Attestation of Conformity is issued on a voluntary basis according to Council Directive 98/37/EC relating to machinery. It confirms that the listed equipment (not annex IV equipment) complies with the principal protection requirements of the directive. See also notes overleaf.

**Test report no.:** 70068483-5

**Date,** 2004-07-08



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1



## EC-Attestation of Conformity

No. M8 04 07 52465 004

**Holder of Certificate:** **Gönka Klima Tesisat Insaat  
San. ve Tic. A.S.**  
Göktürk Cad. No:6  
06460 Sincan-Ankara  
Turkey

**Product:** **Machinery  
Fan Coil**

**Model(s):** **Series SG with types:  
SGS 221, 224, 233, 247, 272  
SG 24, 26, 210, 213, 218**

**Parameters:** **Rated Voltage: 230 V (connection with connector)  
Rated Frequency: 50 Hz  
Protection Class: I  
Protection against  
Moisture: IP 52**

**Tested according to:** **EN 60204-1:1997  
EN 292-1:1991  
EN 292-2/A1:1995  
EN 294:1992  
EN 1050:1996**

This EC Attestation of Conformity is issued on a voluntary basis according to Council Directive 98/37/EC relating to machinery. It confirms that the listed equipment (not annex IV equipment) complies with the principal protection requirements of the directive. See also notes overleaf.

**Test report no.:** 70068483-4

**Date,** 2004-07-08



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1



## EC-Attestation of Conformity

No. M8 04 07 52465 006

**Holder of Certificate:** **Gönka Klima Tesisat Insaat  
San. ve Tic. A.S.**  
Göktürk Cad. No:6  
06460 Sincan-Ankara  
Turkey

**Product:** **Machinery  
Steam Humidifier**

**Model(s):** **Series GON / GOR with types  
GON / GOR 10, 20, 30, 50, 80, 100, 130**

**Parameters:**

Rated Voltage:	400 V
Rated Frequency:	50 Hz
Protection Class:	
Protection against Moisture:	IP 54

**Tested  
according to:**

- EN 60204-1:1997
- EN 292-1:1991
- EN 292-2/A1:1995
- EN 294:1992
- EN 1050:1996
- EN 60335-2-35:2003

This EC Attestation of Conformity is issued on a voluntary basis according to Council Directive 98/37/EC relating to machinery. It confirms that the listed equipment (not annex IV equipment) complies with the principal protection requirements of the directive. See also notes overleaf.

**Test report no.:** 70068483-6

**Date,** 2004-07-08



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1



## EC-Attestation of Conformity

No. M8 04 07 52465 002

**Holder of Certificate:** **Gönka Klima Tesisat Insaat  
San. ve Tic. A.S.**  
Göktürk Cad. No:6  
06460 Sincan-Ankara  
Turkey

**Product:** **Machinery  
Air Handling Unit GKS**

**Model(s):** **Series GKS with types:  
GKS 28 - GKS 125**

**Parameters:**

Rated Voltage:	400 V
Rated Frequency:	50 Hz
Protection Class:	I
Protection against Moisture:	IP 54

**Tested  
according to:**

EN 60204-1:1997
EN 292-1:1991
EN 292-2/A1:1995
EN 294:1992
EN 1050:1996

This EC Attestation of Conformity is issued on a voluntary basis according to Council Directive 98/37/EC relating to machinery. It confirms that the listed equipment (not annex IV equipment) complies with the principal protection requirements of the directive. See also notes overleaf.

**Test report no.:** 70068483-1

**Date,** 2004-07-08



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1



## EC-Attestation of Conformity

No. M8 04 04 52465 001

**Holder of Certificate: Gönka Klima Tesisat Insaat  
San. ve Tic. A.S.**

Göktürk Cad. No:6  
06460 Sincan-Ankara  
Turkey

**Product: Machinery  
Air cooled liquid chiller**

This EC Attestation of Conformity is issued on a voluntary basis according to Council Directive 98/37/EC relating to machinery. It confirms that the listed equipment (not annex IV equipment) complies with the principal protection requirements of the directive. See also notes overleaf.

**Test report no.: 70068483**



**Date, 2004-04-30**



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

**EC-Attestation of Conformity**  
**No. M8 04 04 52465 001**



**Model(s):**                    **GHSC-V :**  
**1V1, 1V2, 1V3, 1V4, 1V6, 1V8, 2V2, 2V3,**  
**2V4, 2V6, 2V8, 2V10, 3V3, 3V4, 4V4**  
**GHSC :**  
**25.1, 40.1, 50.1, 60.2, 70.2, 80.2, 100.2,**  
**120.3, 150.3, 200.4, 240.6, 300.6**

**Parameters:**                    **Rated Voltage:**                    **400 V**  
**Rated Frequency:**                    **50 Hz**  
**Protection Class:**  
**Protection Against Moisture:**                    **IP 54**

**Tested according to:**                    **EN 60204-1:1997**  
**EN 292-2/A1:1995**  
**EN 292-1:1991**  
**EN 1050:1996**